



(2004)量认(国)字(B0585)号

National Test Center of Polymer & Building Materials



No.L1049

No.2004 (X)0183

CUSTOMER: Fangxing Building Materials Co., Ltd.

SAMPLES FOR TESTING

Name: Reinforced PVC corrugated sheet coated with Gelay

Manufacturer: Fangxing Building Materials Co., Ltd.

Appearance: Red corrugated sheet

DATE OF RECEIPT: 2004-04-21

TEST PERIOD: 2004-04-21 to 2004-08-30

THIS REPORT COMPRISES 2 PAGES.

DIRECTOR: 李经纬

DATE: 2004.08.30



Address: No. 14, beisanhuandonglu, Chaoyang district, Beijing, China Post Code: 100013
Tel: +86(0)1064208747, +86(0)1064200694, +86(0)1064216131-2479, 2484, 2436, 2465
Fax: +86(0)1064208747, +86(0)1064216131-2485
E-mail: plastic-test@brici.ac.cn Web site: www.plastic-test.net



(2004)量认(国)字(B0585)号

National Test Center of Polymer & Building Materials




No.L1049

TESTING RESULTS

No. 2004 (X)0183

No.	Item	Result	Test Methods
1	Falling weight impact resistance (-10°C, 10times)	0/10	GB/T 8814-1998
2	Freeze-thaw cycling test(10 cycles)	No bubble, crack and stain.	JG 149-2003

(HEREINAFTER IS EMPTY)



Test: 孙泉 胡孝义

Check: 刘小春

Director: 李业德